

19 Inch Rack Standard

- 1) Front panel width must be 19" (482.6 mm).
- 2) Horizontal spacing of front panel holes must be 18 5/16" (465.1 mm).
ie: holes must be 11/32" (8.73 mm) from panel edge
- 3) Panel height must be an integral number of rack units (RU).
One rack unit is 1.75" (44.45 mm).
- 4) Equipment depth is not defined.
- 5) Equipment width should be less than about 440mm.
- 6) Panel is attached using M6 phillips head screws, Clip-in M6 cage nuts are mounted on the frame. 3/8" square holes are provided for these. 3/8" square holes are provided for these.

